



Bid Questions and Answers Report

Date & Time:

12/8/2021 9:10:57 AM

District Address: District 4 Construction Office, located at 3400 West Commercial Blvd. Fort Lauderdale, FL 33309

District Phone: (954) 777-4130

Proposal: T4589

Project: 441579-1-52-01

Letting Date: 12/8/2021

Localtion: CENTRAL OFFICE

Description: SW 184TH AVE

Question: 36217: Is a 4" curb pad required on the project? Posted: 11/23/2021 10:09:45 AM

Answer: yes Status: ANSWER PUBLISHED

Posted: 11/29/2021 9:31:28 AM

Question: 36218: Could you please provide the flow line elevation of the existing pipe on the drainage sheet? Posted: 11/23/2021 10:10:31 AM

Answer: The as built information is provided in the drainage structure sheets. We were unable to verify the datum and for that reason we added a note asking the contractor to verify in the field. Status: ANSWER PUBLISHED

Posted: 11/29/2021 9:29:27 AM

Question: 36219: could you identify the sodding that will be placed on the project? Posted: 11/23/2021 10:11:37 AM

Answer: St. Augustine Status: ANSWER PUBLISHED

Posted: 11/23/2021 10:34:44 AM

Question: 36240: Are there any MH and valve adjustments on the project? Posted: 11/23/2021 1:54:02 PM

Answer: No Status: ANSWER PUBLISHED

Posted: 11/29/2021 7:48:58 AM

Question: 36266: under what pay item will the tree removals be paid? Posted: 11/29/2021 9:40:42 AM

Answer: Tree removals will be paid under clearing & grubbing = 110-1-1. Status: ANSWER PUBLISHED
Posted: 11/29/2021 10:13:06 AM

Question: 36267: what does sacrificial milling layer noted on sheet 21 of 60 of the estimates-Quantities sheet reference? Posted: 11/29/2021 9:55:31 AM

Answer: The widening is to be constructed to the final grade and then the full bicycle lane will be milled and resurfaced. Status: ANSWER PUBLISHED
Posted: 11/29/2021 12:24:06 PM

Question: 36281: Pay Item no. 0110 22 shows 51 each for the tree root and branch pruning. Yet on the tree disposition sheets 71-77 of the documents there are 68 each identified. could you please clarify the number for each root and each branch pruning separately? Posted: 11/30/2021 8:36:25 AM

Answer: We've re-reviewed the plans, and the total number of trees requiring Root and Branch pruning is 54. All 54 trees are designated for root pruning, and 23 of those trees are also indicated for branch pruning. Per the BOE, the quantities are per tree and include either or both activities. We're unsure where the number of 68 is coming from. Status: ANSWER PUBLISHED
Posted: 12/3/2021 10:39:59 AM