



Bid Questions and Answers Report

Date & Time: 12/8/2021 9:12:59 AM

District Address: District 5 Construction Office, located at 719 South Woodland Blvd, Deland, FL 32720

District Phone: (386) 943-5350

Proposal: T5721

Project: 442875-1-52-01

Letting Date: 12/8/2021

Localtion: CENTRAL OFFICE

Description: SR 44

Question: 36265: On Item 0515-1-2, Sheet 15 shows the guiderail with an ADA handrail.
None of the slopes on the guiderail exceed 5%, so a handrail should not be needed.
Can you confirm that an ADA handrail is not needed?

Posted: 11/29/2021 8:26:05 AM

Answer: A handrail will not be required if the thresholds shown in Note 5 on Index 515-070, Sheet 1 of 5, of the Standard Plans are not exceeded.

Status: ANSWER PUBLISHED

Posted: 11/30/2021 8:58:53 AM