



Bid Questions and Answers Report

Date & Time: 12/8/2021 9:14:31 AM

District Address: District 6 Construction Office, located at 1000 NW 111 Ave, Miami, FL 33172

District Phone: (305) 640-7448

Proposal: T6517

Project: 443898-1-52-01

Letting Date: 12/8/2021

Localtion: CENTRAL OFFICE

Description: SR 5/US 1/OVERSEAS HWY

---

Question: 36280: Item 0515-2-311 is called out as 42" Pedestrian/Bicycle Railing. However, Note 3 on Sheet 6, FIN 443920-1-52-01, says 48" Posted: 11/30/2021 7:13:15 AM

Please clarify if you want 42" or 48" railing.

---

Answer: It should be 42" railing. Status: ANSWER PUBLISHED

Posted: 11/30/2021 1:01:37 PM