



Bid Questions and Answers Report

Date & Time:

1/27/2021 8:27:16 AM

District Address: District 5 Construction Office, located at 719 South Woodland Blvd, Deland, FL 32720

District Phone: (386) 943-5350

Proposal: T5708

Project: 441014-1-52-01

Letting Date: 1/27/2021

Localtion: CENTRAL OFFICE

Description: SR 44

---

Question: 32202: There's no pay item listed in the summary of quantities for temporary pavement markers (0102-78). Will this pay item be added prior to the bid date? Posted: 1/18/2021 11:27:49 AM

---

Answer: The quantites for temporary pavement markers will be the same as the quantities for pavement markers shown under the pay item 710-90 PAINTED PAVEMENT MARKINGS, FINAL SURFACE. One additional application for TTCP will be included under 710-90. Status: ANSWER PUBLISHED  
Posted: 1/22/2021 5:59:38 PM

---

Question: 32210: You show no temporary pavement marking pay items except for 8" white & 18" white. Judging by the typical section you are putting Structural Course on the first 7 miles of the project. Which you would usually have temporary markings. Can you clarify if there is indeed only 2 items for temporary paint? Posted: 1/18/2021 2:32:24 PM

---

Answer: The quantites for temporary pavement markings will be the same as the quantities for painted pavement markings shown under the pay item 710-90 PAINTED PAVEMENT MARKINGS, FINAL SURFACE. One additional application for TTCP will be included under 710-90. Status: ANSWER PUBLISHED  
Posted: 1/22/2021 6:00:04 PM

---

Question: 32343: I appears that the quantity of OBG 09, both Ty B 12.5 only and OBG 09, exceed the given quantity. Can this be looked at? Posted: 1/22/2021 8:16:43 AM

---

Answer: The quantites are to be bid as shown in the plans. Status: ANSWER PUBLISHED  
Posted: 1/22/2021 6:00:28 PM

---

Question: 32344: There doesn't appear to be a typical section that shows the use of OBG 10. Where is this base being utilized? Posted: 1/22/2021 8:17:54 AM

---

Answer: OBG 10 is being utilized to pay for 6" of B-12.5 base at the locations shown on Sheet SQ-13.

Status: ANSWER PUBLISHED

Posted: 1/22/2021 6:01:09 PM