



Bid Questions and Answers Report

Date & Time:

1/27/2021 8:28:24 AM

District Address: District 5 Construction Office, located at 719 South Woodland Blvd, Deland, FL 32720

District Phone: (386) 943-5350

Proposal: T5710

Project: 441366-1-52-01

Letting Date: 1/27/2021

Localtion: CENTRAL OFFICE

Description: SR 40

Question: 31986: Gue to the plans calling for OBG 15 for the widening areas in addition to asphalt base curd pad for the Type E curb, is it necessary to have type b stabilization in those areas? please confirm Type B qty's. Posted: 1/6/2021 5:14:05 PM

Answer: Yes, Type B Stabilization is required in those areas. The quantities are correct. Status: ANSWER PUBLISHED
Posted: 1/21/2021 3:20:58 PM