



Bid Questions and Answers Report

Date & Time: 3/31/2021 10:15:53 AM

District Address: District 2 Construction Office, located at 1109 South Marion Avenue, Lake City, FL 32025

District Phone: (386) 961-7434

Proposal: T2796  
Project: 441194-1-52-01  
Letting Date: 3/31/2021  
Localtion: CENTRAL OFFICE  
Description: SR 10 (ATLANTIC BLVD)

---

Question: 33164: On pages L-6 and L-7 of the Beaches Energy lighting plans, both pages indicate conduit should be 3". However, Beaches Energy Table A-2 indicates "GRAY ELECTRICAL HDPE 2" CONDUIT - SDR 11". Can the department please verify what size the conduit should be? Posted: 3/9/2021 4:38:40 PM

---

Answer: The Table A for441194-1 specifies 2" conduit.  
The Table A for443553-1 specifies 3" conduit. Status: ANSWER PUBLISHED  
Posted: 3/10/2021 10:15:28 AM