



Bid Questions and Answers Report

Date & Time:

5/26/2021 8:35:02 AM

District Address: District 3 Construction Office, located at 1074 Highway 90 East, Chipley, FL 32428

District Phone: (850) 415-9713

Proposal: T3741

Project: 441593-1-52-01

Letting Date: 5/26/2021

Localtion: CENTRAL OFFICE

Description: SR 8 (I-10)

---

Question: 34155: Will we be permitted to utilize the I-10 median crossover east of the Florida / Alabama state line? Posted: 5/17/2021 8:52:40 AM

---

Answer: No Status: ANSWER PUBLISHED

Posted: 5/17/2021 1:58:06 PM

---

Question: 34219: The legend on plan sheets 55 - 64 shows a "R" for Slab Reinforced with W.W.F. 6x6 - W2.9xW2.9, however the plan layout does not show where these will be required. Can you please provide these locations? Posted: 5/18/2021 5:06:41 PM

---

Answer: Please disregard the "R" designation in the legend on sheets 55-64. There are no slabs with W.W.F. on this project. Status: ANSWER PUBLISHED

Posted: 5/20/2021 12:20:26 PM