



Bid Questions and Answers Report

Date & Time: 11/17/2021 8:05:47 AM

District Address: District 3 Construction Office, located at 1074 Highway 90 East, Chipley, FL 32428

District Phone: (850) 415-9713

Proposal: T3712

Project: 439371-1-52-01

Letting Date: 11/17/2021

Localtion: CENTRAL OFFICE

Description: CR 67

---

Question: 35937: Will the Department allow the contractor to place a crane on the ACROW bridge as it is being constructed/removed across Yellow Creek? Posted: 10/25/2021 1:03:38 PM

---

Answer: See Florida Department of Transportation - July 2021 Standard Specifications for Road and Bridge Construction - Specification 7-7- Control of Contractor's Equipment. In addition to these requirements, if a crane is allowed to operate on the temporary bridge, either crane mats or 3/4" plywood must be used under the tracks to protect the decking. Status: ANSWER PUBLISHED  
Posted: 10/26/2021 9:09:13 AM

---

Question: 35938: Please clarify the Test Pile lengths. The Pile Data Table and the Summary of Quantities sheet show different information. Posted: 10/25/2021 1:22:59 PM

---

Answer: Revision forthcoming. Status: ANSWER PUBLISHED  
Posted: 11/3/2021 12:12:23 PM