



Bid Questions and Answers Report

Date & Time: 11/17/2021 8:07:01 AM

District Address: District 3 Construction Office, located at 1074 Highway 90 East, Chipley, FL 32428

District Phone: (850) 415-9713

Proposal: T3814

Project: 439892-1-52-01

Letting Date: 11/17/2021

Localtion: CENTRAL OFFICE

Description: SR 75 (US 231)

Question: 36009: Signal Plans - Pay item# 630-2-27 Conduit F&I Jack and Bore under Railroad - quantity 65 LF: Please provide all that is required to install this. Is a casing required?? If so, what size? Is permitting and flaggers required from the Railroad? Posted: 11/3/2021 11:24:34 AM

Answer: Please see FDOT Standard Specifications for Road and Bridge Construction, July 2021, SECTION 556 JACK AND BORE. No permits are required from the Railroad, but the Railroad will require coordination in the form of plans review and approval of method. Flaggers will be required for work within the Railroad Right-of-Way. Status: ANSWER PUBLISHED
Posted: 11/9/2021 3:21:50 PM