



Bid Questions and Answers Report

Date & Time: 10/27/2021 9:21:04 AM

District Address: District 5 Construction Office, located at 719 South Woodland Blvd, Deland, FL 32720

District Phone: (386) 943-5350

Proposal: T5733

Project: 443815-1-52-01

Letting Date: 10/27/2021

Localtion: CENTRAL OFFICE

Description: SR 40

---

Question: 35611: The PDF plans for this project are formatted letter size paper as opposed to ledger (11 x 17"). please provide reformatted plans in 11" x 17". Posted: 9/24/2021 2:32:24 PM

---

Answer: The requested set of plans have been uploaded in the Contract Proposal Processing (CPP) Online Ordering System. See the following link:  
<https://fdotwp1.dot.state.fl.us/contractproposalprocessingonlineordering/> Posted: 9/28/2021 3:11:33 PM

---

Question: 35796: Bid Item 0515-1-2 and Summary of Railing sheet SQ-11 call for pipe guiderail, which is Index 515-070. Sheet 33 of the plans call for 42" pedestrian railing, which is Index 515-052. Please clarify. Posted: 10/13/2021 1:54:37 PM

---

Answer: Pay Item No. 0515-1-2 Pipe Guiderail (Aluminum) is correct and will be used on Sheet No. 33. Status: ANSWER PUBLISHED  
Posted: 10/14/2021 2:54:38 PM