



Bid Questions and Answers Report

Date & Time:

4/27/2022 8:09:55 AM

District Address: District 3 Construction Office, located at 1074 Highway 90 East, Chipley, FL 32428

District Phone: (850) 415-9713

Proposal: T3806

Project: 439733-1-52-01

Letting Date: 4/27/2022

Localtion: CENTRAL OFFICE

Description: SR 85 (EGLIN PKWY)

---

Question: 37994: The pay items for the referenced project include 0120-1-2 Borrow Excavation, Truck Measure - 22,962 CY as well as 0570-1-3 Performance Turf, Sod and Soil - Shoulder Treatment Index 570-010 - 83,878 SY. Will the Select Fill that is to be furnished and spread to build the shoulders to match the projects cross sections be paid for as 0120-1-2 Borrow Excavation, Truck Measure?

Posted: 4/18/2022 4:21:23 PM

The roadway plan typical sections depict the use of the Treatment II Sod Shoulder Treatment, however the road is not receiving a 3" or more overlay, according to Index 570-010.

---

Answer: The 570-1-3 items for performance turf (sod and soil) is included because the existing shoulders are approximately 3' below the existing pavement edge and should be reworked in accordance with index 570-010. This sod and shoulder rework item includes the material necessary to bring the shoulders up to grade to meet the 570-010 index and the additional soil is included in the area (SY) item. The performance turf items are summarized on sheets SQ-11 for 439733-1 and SQ-6 for 439736-1. The borrow excavation, truck measure item 120-2-2 is summarized on sheets SQ-5 for 439733-1 and SQ-3 for 439736-1 and is derived from the RRR cross sections provided and includes fill in areas for guardrail extensions, roadway reconstruction areas and for the widening for the turn lanes being added along the roadway and any other areas needing select fill other than the shoulder rework areas.

Status: ANSWER PUBLISHED

Posted: 4/22/2022 5:16:41 PM

---

Question: 38103: The Temporary Traffic Control Plans Note, "The Speed limit shall remain as posted thru active work zones except during construction activities during which the speed limit will be reduced per index 102-670."

Posted: 4/20/2022 11:12:18 AM

According to Index 102-670 Speed limits of 55 mph require the use of a Motorist Awareness System and do not reduce the speed of 55 MPH zone.

There are areas with a max speed of 55 mph throughout the project and no pay items are listed for the equipment needed for the MAS System.

Will the speed limit be lowered throughout project limits to eliminate the need for the MAS system or will the MAS system pay items be added to the bid?

---

Answer: Standard Plan Index 102-670 was removed from the 2021-2022 Standard Plans. Note 4, Last sentence is removed and replaced with the following "THE SPEED LIMIT SHALL REMAIN AS POSTED THRU THE ACTIVE WORK ZONES"

Status: ANSWER PUBLISHED

Posted: 4/22/2022 5:12:59 PM

---

Question: 38105: General Note 7 on Roadway Plan Sheet No. 15 states, "For any questions or concerns with Eglin Air Force Base, the contractor can contact Mr. Tom Tobert, Community Planner at (850) 882-6993."

Posted: 4/20/2022 11:21:27 AM

This number reaches an Analyst at Eglin AFB, Mathew Woods. Mathew has no knowledge of the project and says Tom Tobert is not a recognize name in their personnel system.

Please provide another contact for Eglin AFB.

---

Answer: Mr. Tom Tolbert is no longer with the Planning Department with Eglin AFB. The new contact is Mr. Jack Kiger and his contact information is as follows:

Status: ANSWER PUBLISHED

Posted: 4/22/2022 5:00:53 PM

Mr. Jack Kiger  
Direct Phone: 850-882-8078  
Alt. Phone: 850-855-9685  
Email: john.kiger@us.af.mil