



Bid Questions and Answers Report

Date & Time: 4/27/2022 8:16:43 AM

District Address: District 6 Construction Office, located at 1000 NW 111 Ave, Miami, FL 33172

District Phone: (305) 640-7448

Proposal: T6514

Project: 444622-1-52-01

Letting Date: 4/27/2022

Localtion: CENTRAL OFFICE

Description: SR 112 (I-195) (JULIA TUTTLE CSWY) AND SR 907 (ALTON RD)

---

Question: 38112: Please provide the minimum thickness of the temporary asphalt required on this project. Posted: 4/20/2022 3:36:27 PM

---

Answer: Temporary asphalt thickness is one inch. Status: ANSWER PUBLISHED

Posted: 4/21/2022 11:59:05 AM