

Bid Questions and Answers Report

Date & Time:

1/26/2022 8:53:41 AM

District Address:

District 4 Construction Office, located at 3400 West Commercial Blvd. Fort

Lauderdale, FL 33309

District Phone:

(954) 777-4130

Proposal:

T4591

Project:

438118-1-52-01

Letting Date:

1/26/2022

Localtion:

**CENTRAL OFFICE** 

Description:

**BAYVIEW DR** 

Question:

36548: In reference to Item 0285-704-Optional Base 04, in the Typical Sections it does not specify the Base Option.However on sheet SQ-17 it says " earthwork has been calculated using the Type B-12.5 option". Can the Contractor use whichever base option is most convinient for them? Additionally it is normal to use 6" Limerock Base for asphalt driveway but it is not for widening, in this case, we have both situation.

Please advise

Posted: 1/18/2022 12:17:46 PM

Answer:

The typical sections specify Optional Base Group 4 for widening sections (sheets 8, 9, 10, 12). The contactor may use any of the base options as defined in the spec book for Optional Base Group 4. Plans also specify the use of Optional Base Group 4 for the driveways (sheet 75). The use of 6' limerock for driveways is common.

Status:

ANSWER PUBLISHED

Posted: 1/19/2022 1:02:07 PM