




Florida Department of Transportation

RON DESANTIS
GOVERNOR

Florida's Turnpike Enterprise
P.O. Box 613069, Ocoee, FL 34761
407-532-3999

JARED W. PERDUE, P.E.
SECRETARY

ADDENDUM NO. 3

DATE: November 8, 2023
TO: PROPOSERS
FROM:  Richard M. Nethercote, Jr.
District Contracts Administrator
Florida's Turnpike Enterprise
SUBJECT: Contract No.: E8V22
Financial Project No.: 430565-4-72-02
Counties: Clay & Duval

Project Name: Asset Maintenance – Zone 5

PROPOSALS TO BE RECEIVED: November 19, 2024, 5:00 PM Local Time.

Proposers and other interested parties are informed that the above-referenced documents are hereby revised, changed and supplemented as set forth below:

Revised Scope of Services

The following language has been added to the Scope of Services:

4.3.8.1 HVAC, Emergency Generators, Fuel Tanks, Automatic Transfer Switches (ATS), Electrical, Life Safety, Roof and Fire Protection & Suppression Systems

All HVAC equipment and systems shall be fully operational and maintained as designed or better. Refueling of the generator fuel tanks is the responsibility of the Contractor. **Maintenance of fire suppression systems shall be performed as indicated in Attachment 111, Maintenance of Fire Suppression System.**

HVAC, EMERGENCY GENERATORS, FUEL TANKS & AUTOMATIC TRANSFER SWITCHES, ELECTRICAL, LIFE SAFETY, ROOF AND FIRE PROTECTION & SUPPRESSION SYSTEM

All other conditions of the subject contract remain unchanged.

If you are a PROPOSAL HOLDER, please acknowledge receipt of this Addendum on Page 2 of the Form 375-020-56 of your Proposal, and return with your Price Proposal forms.

If you have any questions regarding this information, please do not hesitate to contact Rich Nethercote at 407-264-3885.

ATTACHMENT III

MAINTENANCE OF FIRE SUPPRESSION SYSTEM

Maintenance is defined as annual and semi-annual inspections of the system as required by the manufacturer of the system and the filing of inspection reports with the Department.

All Testing & Inspections for Clean Agent Fire Suppression Systems shall be done in strict accordance to NFPA 72 and 2001 Codes.

The inspections shall have at a minimum the following:

A. Annually (100% Full Functional Test):

- Testing of Panel and Components
- Testing of Batteries
- Testing of Smoke Detectors
- Testing of Pull Stations
- Testing of Horns
- Testing of Horn/Strobes
- Testing of Strobes
- Testing of Bells
- Testing of Aspirating Smoke Detectors
- Inspections of Piping Network
- Inspection of Nozzles
- Inspection of Room Integrity
- Testing of Sequence of Events of how system was initially designed
- Inspection of Tank to verify Agent Weight
- Inspection of Liquid Level Indicator OR weighing if tank Liquid Level is not available

B. Semi-Annually (NFPA 2001):

- Inspection of tank verifying agent quantity

End of Attachment III