



Florida Department of Transportation

RON DESANTIS
GOVERNOR

Florida's Turnpike Enterprise
P.O. Box 613069, Ocoee, FL 34761
407-532-3999

KEVIN J. THIBAUT, P.E.
SECRETARY

ADDENDUM No. 1

DATE: November 24, 2020

TO: PROPOSERS

FROM: *RMM* Richard M. Nethercote, Jr.
District Contracts Administrator
Florida's Turnpike Enterprise

SUBJECT: Contract No.: E8S51
Financial Project No.: 440857-1-52-01
County(ies): Polk

Project Name: All Electronic Toll (AET) Conversion – Polk Pkwy (SR570) (MP 0 to 18)

BIDS TO BE RECEIVED: December 8, 2020 at 2:30 P.M Local Time

Proposers and other interested parties are informed that the above referenced documents are hereby revised, changed and supplemented as set forth below:

PLANS AND PAY ITEMS REVISIONS

Plan sheets and Pay Items for the above-mentioned project have been revised. Please go to the Online Ordering Web Site at <https://fdotwp1.dot.state.fl.us/contractproposalprocessingonlineordering/> to download the Plans Revision from your Order History. Please substitute these sheets for the like-numbered sheets you now have. See the attached Revision Memo for a complete listing of Plans and Pay Items Revisions.

SUPPLEMENTAL SPECIFICATIONS PACKAGE

Please see the attached Transmittal Memo for a description of the modifications to this Contract. The .PDF file of Supplemental Specification Package, E8S51Specs_Supp1, for the above-mentioned Project can be downloaded from your Order History by going to the Online Ordering Web Site at <https://fdotwp1.dot.state.fl.us/contractproposalprocessingonlineordering/>.

AMENDMENT NOTIFICATION

If you are a **BID DOCUMENT HOLDER** for the subject project, please go to the Online Ordering Web Site at <https://fdotwp1.dot.state.fl.us/contractproposalprocessingonlineordering/> to download **E8S51** with "File Type" **.001x** for this Bid Document from your Order History.

If you are a **BID DOCUMENT HOLDER**, in Expedite Bid open the Acceptance of Bidding Acknowledgements folder to confirm your acknowledgement of Amendment and Addenda Files. Failure to load all amendment files will cause the bid to be rejected.

If you have any questions regarding this information, please do not hesitate to contact Rich Nethercote at 407-264-3885.



Florida Department of Transportation

RON DESANTIS
GOVERNOR

605 Suwannee Street
Tallahassee, FL 32399-0450

KEVIN THIBAUT
SECRETARY

TRANSMITTAL OF CONTRACT ADDENDUM


Contract No. **E8S51**
 Letting December 2020
 FPID(s) 440857-1-52-01
 Description All Electronic Toll (AET) Conversion – Polk Pkwy (SR570) (MP 0 to 18)
 County Polk

Contract Addendum No. 1 includes: *See Page 2 for details*

- ✓ Digitally signed + sealed Contract Plan Revision No. 1 (PDF file)
- ✓ Digitally signed + sealed Supplemental Specifications Package Revision No. 1 (PDF file)
- ✓ Design + engineering data (CADD-Rev1.zip file)

Contract time revised No x Yes If yes, total calendar days

- ✓ Addendum package is complete, has no known errors or omissions, has been reviewed for constructability and biddability, and is ready for distribution to contract bidders.

CONCURRENCE: 
 Turnpike Program Management Administrator

DATE: 2020-11-24

CONTRACT ADDENDUM INCLUDES:

PLAN REVISIONS	
SHEET	DESCRIPTION OF MODIFICATION
Roadway Plans 1	Added Sheet Number 2A to Index
Roadway Plans 2A	New Signature Sheet
Roadway Plans 3	AASHTOWare PrP Updated
Roadway Plans 4	AASHTOWare PrP Updated
Roadway Plans 5	AASHTOWare PrP Updated
Roadway Plans 6	AASHTOWare PrP Updated
Roadway Plans 7	Revised Quantity for Pay Item 1501-1 and AASHTOWare PrP Updated
Roadway Plans 8	AASHTOWare PrP Updated
Roadway Plans 584	Revised Note #4
Tolls Facilities Plans 1	Added Sheet Number TF-002A to Index
Tolls Facilities Plans TF-002A	New Signature Sheet
Tolls Facilities Plans TF-016	Revised Quantity for Pay Item 1501-1

PAY ITEMS + QUANTITIES (AASHTOWare PrP) – FPID 440857-1-52-01					
COMPONENT	PAY ITEM	SHEET	ADD MOD DEL	OLD QUANTITY	NEW QUANTITY
Roadway	1501-1	7	MOD	12	9

SUPPLEMENTAL SPECIFICATIONS PACKAGE	
SECTION	DESCRIPTION
TECHNICAL SPECIAL PROVISIONS T120 – TEMPORARY SURCHARGE, Page 49 Section T120-2	Revised 3 rd paragraph: "Install geotextile material (R-2) in accordance with Specification 985 with a minimum long term tensile resistance Ta of 800 lb./ft. (in both machine and cross direction) in the surcharge areas as shown in the Project Plan Set and a minimum TULT of 3,000 lb/ft."