2. SHOP DRAWINGS: This Index is considered fully detailed; only submit shop drawings for minor modifications not included in the Plans.

A. Pole, Arm Tubes, Strut Tubes, Bars, Plates, Stiffeners: ASTM B221, Alloy 6063-T6 or

B. Pole Connection Extrusion Clamp: ASTM B221, Alloy 6061-T6

C. Caps and Covers: ASTM B-26, Alloy 319-F

D. Aluminum Weld Material: ER 4043

E. Transformer and Frangible Base Materials: ASTM B26 or ASTM B108, Alloy 356-T6

F. Base Bolts, Nuts and Washers:

a. Shoe Base Bolts: ASTM F3125, Grade A325, Type 1 b. Nuts: ASTM A563 Grade DH Heavy-Hex

C. Washer: ASTM F436 Type 1

G. Anchor Bolts, Nuts, and Washers: a. Anchor Bolts: ASTM F1554 Grade 55 b. Nuts: ASTM A563 Grade A Heavy-Hex

H. Clamp Hardware: See Sheet 2

I. Stainless Steel Cap Fasteners: ASTM F593 Alloy Group 2, Condition A, CW1 or SH1 J. Nut Covers: ASTM B26 (319-F)

K. Concrete: Class II L. Reinforcing Steel: Specification 415

## 4. FABRICATION:


A. Weld Arm and Pole Alloy in the T4 temper using 4043 filler. Age the Arm and Pole artificially to the T6 temper after welding.

B. Transverse welds are only allowed at the base.

- C. Light Pole Properties: Taper as required to provide a round top O.D. of 8" and a base O.D. of 10" for all pole heights. Portions of the pole near the base shoe and at the arm connections may be held constant to simplify fabrication. Maintain pole wall thickness
- D. Fixture Arm Tube Properties: See Sheet 2.
- Provide 'J', 'S' or 'C' hook at top of pole for electrical wires.
- Perform all welding in accordance with AWS D1.2. G. Identification Tag: (Submit details for approval.)
- a. 2" x 4" (Max.) aluminum identification tag.
- b. Locate on the inside of the transformer base and visible from the door opening.
- c. Secure to transformer base with  $V_8$ " diameter stainless steel rivets or screws.
- d. Include the following information on the ID Tag: 1. Financial Project ID
- 2. Pole Height 3. Manufacturer's Name
- 5. COATINGS/FINISH:
- A. Pole and Arm Finish: 50 grit satin rubbed.
  B. Galvanize Steel Bolts, Screws, Nuts and Washers: ASTM F2329
- C. Hot Dip Galvanize miscellaneous steel items: ASTM A123

## 6. CONSTRUCTION:


- A. Foundation: Specification 455, except payment for the foundation is included in the cost
- B. Frangible Base, Base Shoe, and Pole Connection Extrusion Clamp: a. Certify that the Pole Connection Extrusion Clamp, Frangible Transformer Base, and Base Shoe Design are capable of providing the required capacity, assuming a design wind speed of 160 MPH.
- b. Certify the Base conforms to the FHWA required AASHTO Frangibility Requirements, tested under NCHRP Report 350 Guidelines (e.g. Akron Foundry TB1-17).
- c. Do not erect pole without Luminaire attached.





**REVISION** 11/01/21


FDOT

FY 2022-23 STANDARD PLANS










FOUNDATION ELEVATION


FOUNDATION DEPTHS		
Luminaire Mounting Height	≤ 40 Ft.	45-50 Ft.
Depth	8'-0"	9'-0"

## FOUNDATION NOTES:


- 1. Depths shown are for slopes equal to or flatter than 1:4. For slopes steeper than 1:4 and equal to or flatter than 1:2 add 2'-6" to foundation depths
- 2. Foundation Tie Bars: #4 Tie Bars @ 12" centers (max.) or D10 (or W10) spiral @ 6" pitch, 3 flat turns top and 1 flat turn bottom.



TOP VIEW TRANSFORMER BASE



**BOTTOM VIEW** TRANSFORMER BASE



POLE BASE ELEVATION

FOUNDATION AND BASE DETAILS

11/01/21

DESCRIPTION:

FDOT

FY 2022-23 STANDARD PLANS