

## **Index 400-010 Cantilever Retaining Wall (C-I-P)**

### **Design Criteria**

***AASHTO LRFD Bridge Design Specifications; Structures Design Guidelines (SDG), FDOT Design Manual (FDM)***

### **Design Assumptions and Limitations**

Use this standard with Indexes in the 521-600 Series as appropriate.

The Retaining Wall Standard Drawings consist of **Standard Plans** Index 400-010 and companion Data Tables located in the FDOT Structures Bar Menu as MicroStation CADD cells. These Standard Plan Indexes are intended to work in conjunction with each other and the LRFD Retaining Wall Program, developed by the Structures Design Office.

Design assumptions used in the development of the Standard Drawings may be found in 'Retaining Wall Notes' within the Program. Indexes and Program are intended for C-I-P cantilever retaining walls only, not abutments. At a minimum the EOR should consider the applicability of the following: overall stability, settlement and seismic loading.

The Engineer of Record (EOR) shall be responsible for the Retaining Wall Design in its entirety. The EOR should complete and/or alter the Index drawings to suit the particular design. The EOR should consider the appropriateness of the use of the Standard and Program if the particulars of the design conflict significantly with the assumptions used in the development of the Standards.

These Indexes are intended to work in conjunction with Retaining Wall Control Drawings located within the Plans. The Control Drawings should define geometrics, locations and other specifics of the Retaining Wall such that when used in conjunction with the Index, the Contractor has sufficient information for construction.

**Table 400-010-1 Durability Requirements for Applicable FDOT Wall Type**

Applicable FDOT Wall Types	Durability Requirements			
	Concrete Cover (in) Carbon Steel*	Concrete Cover (in.) (FRP)**	Concrete Class	Pozzolan Additions (Y/N)***
Type 1A	2	2	II	No
Type 1B	2	2	IV	No
Type 1C	3	2	IV	No
Type 1D	3	2	IV	Yes

\* SDG 1.4.2-1

\*\* Structures Manual Volume 4 2.3E

\*\*\*Pozzolan additions are not required for FRP reinforced retaining walls

### Plan Content Requirements

Prepare and include in the plans all Wall Control Drawings and related drawings as specified in **SDM** Chapter 19 and **FDM** 262.

The Program outputs five text files:

- retwall\_line1.txt
- retwall\_line2.txt
- retwall\_line3.txt
- retwall\_line4.txt
- retwall\_line5.txt –use data to calculate concrete and reinforcing steel quantities.

Text files for lines 1-4 correspond sequentially to the four Retaining Wall Data tables contained in the companion Data Tables for Index 400-010. Complete these data tables using the four test files and include the Data Tables in the plans. The test files can be inserted into the tables by using the 'Include' Key-In Utility in MicroStation at the active points in each table. True Type Font, 'FDOT Mono' must be used to align inserted test with table columns.

Complete and add/modify/delete the Retaining Wall Data Table Notes as necessary. If enhanced aesthetics are required, include drawing or reference a texture from Index 534-200 in the Retaining Wall Notes.

See **FDM** 115 for more information regarding use of Data Tables



**Payment:**

<b>Item number</b>	<b>Item Description</b>	<b>Unit Measure</b>
400-2-11	Concrete Class II, Retaining Wall	CY
400-4-11	Concrete Class IV, Retaining Wall	CY
415-1-3	Reinforcing Steel –Retaining Wall	LB
415-10-AA	Fiber Reinforced Polymer Bars	LF

*Commentary: Retaining Wall quantities shall not include concrete or reinforcing for Index 521-600 Series Concrete Barriers/Junction Slabs. See Standard Plans Instructions Index 521-600 Series for Concrete Barrier/Junction Slab Pay Items as required.*

*Refer to [FDM 902](#) for guidance on the Estimated Quantities Report.*