



TABLE OF MAXIMUM PILE PICK-UP AND SUPPORT LENGTHS							
	D = Square Pile Size (inches)					Required Storage and	Dick Up Dotail
	12	14	18	24	30	Transportation Detail	Pick-Up Detail
Maximum Pile Length (Feet)	48	52	59	68	87	2, 3, or 4 point	1 Point
	69	75	85	98	124	2, 3, or 4 point	2 Point
	99	107	121	140	178	3 or 4 point	3 Point



TYPICAL PILE SHAPE FOR MOLD FORMS



DETAIL SHOWING TYPICAL COVER

## PRESTRESSED CONCRETE PILE NOTES:

- 1. Work this Index with the Square Prestressed Concrete Pile Splices (Index 455-002), the Prestressed Concrete Pile Standards (Index 455-012 thru 455-030), the High Moment Capacity Square Prestressed Concrete Pile (Index 455-031) and the Pile Data Table in the Structures Plans.
- 2. Concrete:
  - A. Piles: Class V, except use Class VI for High Moment Capacity Pile (Index 455-031).
  - High Capacity Splice Collar: Class V.
  - See "GENERAL NOTES" in the Structures Plans for locations where the use of Highly Reactive Pozzolans is required.
- 3. Concrete strength at time of prestress transfer:
  - A. Piles: 4,000 psi minimum.
  - High Moment Capacity Piles: 6,500 psi minimum.
- 4. Carbon-Steel Reinforcing:
  - Bars: Meet the requirements of Specification Section 415.
  - Prestressing Strands: Meet the requirements of Specification Section 933.
  - Protect all strands permanently exposed to the environment and not embedded under final conditions in accordance with Specification Section 450.
- 5. Spiral Ties:
  - A. Tie each wrap of the spiral strand to a minimum of two corner strands.
  - One full turn required for spiral splices.
- 6. Pile Splices: Fill dowel holes and form the joint between pile sections with a Type AB Epoxy Compound in accordance with Specification Section 926. Use an Epoxy Bonding Compound or an Epoxy Mortar as recommended by the Manufacturer.