# Index 425-010 Structure Bottoms Type J and P

## **Design Criteria and Guidance**

FDOT Design Manual (FDM); Drainage Manual (DM); Drainage Design Guide (DDG) Structures Manual (SM)

## **Design Assumptions and Limitations**

Check structures with depths over 14' below the mean high-water table for flotation.

Type J Structure bottoms must have a minimum 6'0" wall height when possible, for maintenance access.

Require Class IV Concrete for special applications of structures located in extremely aggressive environments

#### **Plan Content Requirements**

Include Drainage Structure information in the Plans in accordance with the requirements of the Basis of Estimates Manual (*BOE*) and the *FDM*.

Specify Class IV Concrete were required for extremely aggressive environments, see **Structures Manual (SM) 1.3**.

#### **Payment**

Item number	Item Description	Unit Measure
425-1-AAB	Inlet – Drainage	EA
425-2-AAB	Manhole- Drainage	EA
425-3-AAB	Junction Boxes- Drainage	EA

See the **BOE** and **Specification 425** for additional information on payment, pay item use and compensation.