
Index 630-001 Conduit Installation Details

ORIGINATION

Date: July 16, 2018

Name: Ed Cashman

Phone: (850) 414-4314

Email: edward.cashman@dot.state.fl.us

COMMENTARY

COMMENTS AND RESPONSES

BLACK = Industry Review Comments **RED** = Standard Plans Response

Name: Derek Vollmer

Date: 8/31/18

COMMENT:

Sheet 1 of 2: In Figure E, revise the note to reference Note 3, Figure A. or make sure we reference the same note after they are moved and combined into the general notes.

RESPONSE:

Backfill requirements, including the use of Flowable Fill, is included in the Specification 630 (Section 630-3.1).