
Index 635-001 Pull and Splice Boxes

ORIGINATION

Date: 8/1/18

Name: Ed Cashman

Phone: (850) 414-4314

Email: Edward.cashman@dot.state.fl.us

COMMENTARY

COMMENTS AND RESPONSES

BLACK = Industry Review Comments **RED** = Standard Plans Response

Name: Derek Vollmer

Date: 8/31/18

COMMENT:

Place a dimension minimum of 6" between the top of the conduit and the bottom of the lid.
Remove the duplicate Note 6.

RESPONSE:

In the Draft, the 6" Minimum was added from the lid to the top of the ground rod and the conduits are shown graphically below the ground rod.