
Index 515-052 Pedestrian/Bicycle Railing (Steel)

ORIGINATION

Date: September 10, 2019

Name: Cheryl Hudson

Phone: (850) 414-5332

Email: Cheryl.hudson@dot.state.fl.us

COMMENTARY

Sheet 9: Changed Anchor depth for Case I and IIb.

COMMENTS AND RESPONSES

BLACK = Industry Review Comments **RED** = Standard Plans Response

Name: Nick Benedico, P.E.

Date: September 11, 2019

COMMENT:

In the Anchor Bolt Table, should the dimension “C” for Case III be 3” (per the typical section) instead of 4½”?

RESPONSE:

Date: September 12, 2019

The 3” dimension on the typical section is actually to the edge of the base plate. The 4.5” edge distance is not graphically shown in the detail, and is only listed in the table as dimension “B”. The 4.5” edge distance would apply when the plate is on top of the step cheekwall.