
Index 522-002 Detectable Warnings and Sidewalk Curb Ramps

ORIGINATION

Date: August 26, 2019

Name: Rick Jenkins

Phone: 850 414-4355

Email: Rick.Jenkins@dot.state.fl.us

COMMENTARY

Delete General Note 2

COMMENTS AND RESPONSES

BLACK = Industry Review Comments **RED** = Standard Plans Response

Name: Mary Anne Koos

Date: August 23, 2019

COMMENT:

- 1) Gen Note 1c: This 15' max only applies when your chasing grade in a roadway, and not to ramps built as part of structures. Does this need to be clarified?
- 2) Gen Note 2: If a person is designing a custom ramp, is this information somewhere else so that they understand it applies to them? It's a pretty important feature of ramp design.
- 3) Curb ramps don't just occur at sidewalks, can we drop the "sidewalk"?

RESPONSE:

Date: August 26, 2019

- 1) The note specifically references "curb ramps." We do not show ramps to structures in the index.
- 2) This note does not apply to all curb ramps. The specific issue brought to our attention was the ramp in a radial return in which it is not possible to meet this requirement. The details in the Standard Plans Index more accurately depict the proper layout in this situation.
- 3) Further coordination would be needed to implement this recommendation. We will coordinate further with consideration for including the suggestion in the future.