
Index 425-031 Adjacent Barrier Inlet

ORIGINATION

Date: February 13

Name: Tim Holley

Phone: (850) 414-4117

Email: tim.holley@dot.state.fl.us

COMMENTARY

Reorganized Index, Added additional Sheets.

Sheet 1: General Notes.

Sheet 2: Dimensional, Reinforcement, and Steel Grate Details.

Sheet 3: Inlet Collar Dimensional, Reinforcement, and Backwall Plate Details.

Sheet 4: Shoulder Pavement Wrap, Barrier Type Examples, and Structure Bottoms.

COMMENTS AND RESPONSES

BLACK = Industry Review Comments **RED** = Standard Plans Response

Name: Anonymous

Date: September 16, 2020

COMMENT:

Inlet with Structure Bottom – The 3'-8" dimension should be along the B-B section, not A-A.

RESPONSE: The 3'8" dimension in A-A is consistent with an overall dimension of 5'0", minus the wall thickness (8") twice.

No change to Index

Date: 9-18-20