

---

---

## Index 522-002

### Detectable Warnings and Sidewalk Curb Ramps

#### ORIGINATION

**Date:** May 18, 2020

**Name:** Brad Bradley

**Phone:** (950) 414-4295

**Email:** brad.bradley@dot.state.fl.us

#### COMMENTARY

Sheet 1: Deleted General Notes #5: Detectable Warnings - Acceptance Criteria.

Sheet 2: Added Landing to isometric views

Sheet 7: Added New Detail "Curb Ramp Outside Radial Return"

#### COMMENTS AND RESPONSES

**BLACK** = Industry Review Comments    **RED** = Standard Plans Response

**Name:** Rob Phelan

**Date:** September 5, 2020

#### **COMMENT:**

For the Curb Ramp Outside Radial Return detail consider showing the ADA landing area required for pedestrian push buttons for use at signalized intersection. This detail may lead to some placing the Pedestrian Assembly and corresponding push button in the sloped portion of the curb ramp.

**RESPONSE:** Pushbuttons are not shown within Index 522-002 because placement must be determined based on-site specific conditions and shown in the Contract Plans. The MUTCD provides multiple options to address pushbutton location. In addition, designers should consider whether automatic recall or passive detection can be applied to eliminate the need for a pushbutton.

**No change to Index**

**Date:** 9-14-20