
Index 425-031 Adjacent Barrier Inlet

ORIGINATION

Date: May 11, 2023

Name: Shae Gibbs

Phone: (850) 414-4314

Email: Shae.Gibbs@dot.state.fl.us

COMMENTARY

The general notes were updated on a previous year and this information was deleted in the revision process. Adding back clarification that the bar installation is only limited with the galvanized grate.

COMMENTS AND RESPONSES

BLACK = Industry Review Comments **BLUE** = Standard Plans Response **GREEN** = Change Made to Index

Name: Raymond Valido

Date: 6/1/2023

COMMENT: Confirm "Alternate G" is correct. The current version of 425-031 uses "Alternate B".

RESPONSE: "Alt. G" is the term used when the grate is to be galvanized. We will change the note to read "Alt. G" instead of "Alternative G"

CHANGE MADE TO INDEX: Yes: Change note to "Do not field install roller bars when Alt. G grates are specified in the Plans in accordance with Specification 425."

Response Date: 6/1/2023