ORIGINATION FORM -

Proposed Revisions to a Standard Plans Index

(Please provide all information — Incomplete forms will be returned)

Standard Plans: Index Number: 425-031

Sheet Number (s): 1

Index Title: Adjacent Barrier Inlet

Contact Information:

Date: April 17, 2023 Originator: Shae Gibbs Phone: (850) 414-4314

Email: shae.gibbs@dot.state.fl.us

Summary of the changes:

Sheet 1: General Note 5 changed to "Do not field install roller bars when Alt. G grates are specified in the Plans in accordance with Specification 425."

Commentary / Background:

The general notes were updated on a previous year and this information was deleted in the revision process. Adding back clarification that the bar installation is only limited with the galvanized grate.

Other Affected Offices / Documents: (Provide name of person contacted)

Yes No

- Other Standard Plans –
- 🔲 🗹 FDOT Design Manual –
- 🔲 🗹 Basis of Estimates Manual –
- Standard Specifications –
- 🛛 🗹 Approved Product List –
- Construction –
- 🔲 🗹 Maintenance –

Origination Package Includes: (Submit package to Rick Jenkins)

Yes N/A

- Redline Mark-ups
 - Revised or Proposed Standard Plan Instruction (SPI)
- Other Support Documents

Implementation:

- Design Bulletin (Interim)
 DCE Memo
 Brogram Mamt, Bulletin
 - Program Mgmt. Bulletin
 - ✓ FY-Standard Plans (Next Release)

 +

GENERAL NOTES:

1. Work this Index with Index 425-001 and Index 425-010.

- 2. When called for in the Plans, use this inlet in conjunction with median or shoulder barrier per Index 521-001 or a barrier with junction slab and wall coping per Index 521-610.
- 3. Reinforce the upper 2'-3" of the inlet in accordance with sections CC, DD, and EE regardless of construction method.
- 4. Chamfer exposed edges and corners to $\frac{3}{4}$ " or tool to $\frac{1}{4}$ " radius,
- 5. *Field installation of a roller bar will not be permitted.* Adjust tolerance during fabrication or casting, or, match grate to structure prior to galvanizing.
- 6. Use Grade 60, #4 bars for reinforcing steel. See Index 425-001 for equivalent area of welded wire fabric.
- 7. Dimensions are for both precast and cast-in-place inlets unless otherwise noted.
- 8. Anchor bolts: Use either ASTM A307 hex head bolts cast-in-place, or ASTM A36 or F1554 (Grade 36) galvanized fully threaded rod, adhesive bonded anchors installed in accordance with Specification 416. Rods must be a minimum of 6" long with 4" minimum embedment with one ASTM 194 or A563 heavy hex head nut and one ASTM F436 flat washer each. Hot-dip galvanize anchor bolts, nuts, and washers.
- 9. Reduce Cross Slope: Use a flatter cross slope as required to match adjacent grading per the Plans. Reduce vertical dimensions and bar spacing as needed to maintain concrete cover as shown.

TABLE OF CONTENTS:			
Sheet	Description		
1	General Notes and Contents		
2	Dimensional, Reinforcing, and Steel Grate Details		
3	Inlet Collar Dimensional, Reinforcing, and Backwall Plate Details		
4	Shoulder Pavement Wrap, Barrier Type Examples, and Structure Bottoms		

Do not field install roller bars when Alt. G grates are specified in the Plans in accordance with Specification 425.



= ADJACENT BARRIER INLET (Shoulder Barrier Similar)

LAST NOISI REVISION ISIN 10/01/20

N UESCRIPTION:



FY 2023-24 STANDARD PLANS

ADJACENT BARRIER IN

- Inlet - Inlet Shoulder Pavement Edge of Pavement		
ILET	INDEX 425-031	sнеет 1 of 4

GENERAL NOTES:

- 1. Work this Index with Index 425-001 and Index 425-010.
- 2. When called for in the Plans, use this inlet in conjunction with median or shoulder barrier per Index 521-001 or a barrier with junction slab and wall coping per Index 521-610.
- 3. Reinforce the upper 2'-3" of the inlet in accordance with sections CC, DD, and EE regardless of construction method.
- 4. Chamfer exposed edges and corners to $\frac{3}{4}$ " or tool to $\frac{1}{4}$ " radius.
- 5. Do not field install roller bars when Alt. G grates are specified in the Plans in accordance with Specification 425. Adjust tolerance during fabrication or casting, or match grate to structure prior to galvanizing.
- 6. Use Grade 60, #4 bars for reinforcing steel. See Index 425-001 for equivalent area of welded wire fabric.
- 7. Dimensions are for both precast and cast-in-place inlets unless otherwise noted.
- 8. Anchor bolts: Use either ASTM A307 hex head bolts cast-in-place, or ASTM A36 or F1554 (Grade 36) galvanized fully threaded rod, adhesive bonded anchors installed in accordance with Specification 416. Rods must be a minimum of 6" long with 4" minimum embedment with one ASTM 194 or A563 heavy hex head nut and one ASTM F436 flat washer each. Hot-dip galvanize anchor bolts, nuts, and washers.
- 9. Reduce Cross Slope: Use a flatter cross slope as required to match adjacent grading per the Plans. Reduce vertical dimensions and bar spacing as needed to maintain concrete cover as shown.

TABLE OF CONTENTS:			
Sheet	Description		
1	General Notes and Contents		
2	Dimensional, Reinforcing, and Steel Grate Details		
3	Inlet Collar Dimensional, Reinforcing, and Backwall Plate Details		
4	Shoulder Pavement Wrap, Barrier Type Examples, and Structure Bottoms		





Inlet		
LET	INDEX	SHEET
	425-031	Tot 4