

---

## Index 400-011 Gravity Wall

### ORIGINATION

**Date:** 4/11/2024

**Name:** Joshua Turley

**Phone:** 414-4475

**Email:** Joshua.turley@dot.state.fl.us

### COMMENTARY

Rebar detailer raised the issue that the 3 ½" hook shown for BAR B can't be bent. It's too short and not a standard hook. Followed up with a fabricator and the fabricator agreed a 3 ½" hook can't be bent without slippage.

### COMMENTS AND RESPONSES

**BLACK** = Industry Review Comments   **BLUE** = Standard Plans Response   **GREEN** = Change Made to Index

**Name:** Alex Lawrence

**Date:** 6/19/24

**COMMENT:** Remove reference to Spec 455 for spread footer foundations. Excavation areas should be proof rolled for footer but need to eliminate requirement to get a modified proctor on existing material and lose week plus to get proctor and take density on existing material.

Understand requirement for fill section but not cut section.

**RESPONSE:** Comments are not related to the change made in the Standard. If these comments were upheld, they should be a change to the Spec not the Standard. The Standard still needs to reference a Spec.

**CHANGE MADE TO INDEX:** No

*Response Date:* 7/10/24