

---

## Index 455-112

### 12” Square CFRP & SS Prestressed Concrete Pile

#### **ORIGINATION**

**Date:** 8/21/24

**Name:** Joshua Turley

**Phone:** 850-414-4475

**Email:** Joshua.turley@dot.state.fl.us

#### **COMMENTARY**

This is a more accurate representation of the nominal diameter driven by the fact that the strands are fabricated in millimeters not inches.

#### **COMMENTS AND RESPONSES**

**BLACK** = Industry Review Comments    **BLUE** = Standard Plans Response    **GREEN** = Change Made to Index

**Name:** Hisham Sunna

**Date:** 8/23/24

**COMMENT:** Has there been any issue with calling out 1/2" strand and 0.6" strand? we have been calling them out this way for decades and it is known what is being called out. Suggest leaving as is - might be confusing when searching for a different callout.

**RESPONSE:** This change originated from a question/concern from a strand fabricator. Those who are familiar with 0.6 diameter will still know that it is nominally 0.62. This clears up any concern that the fabricators may have that they are not supplying the correct strand.

**CHANGE MADE TO INDEX:** No.

*Response Date:* 8/27/24