
Index 460-470 Traffic Railing - (Thrie-Beam Retrofit) Typical Details & Notes

ORIGINATION

Date: 5/7/24

Name: Joshua Turley

Phone: 414-4475

Email: Joshua.turley@dot.state.fl.us

COMMENTARY

Upon completion of new research we are allowing screw anchors as an option as an alternative to adhesive anchors.

COMMENTS AND RESPONSES

BLACK = Industry Review Comments **BLUE** = Standard Plans Response **GREEN** = Change Made to Index

Name: Greg Grant

Date: 8/15/24

COMMENT: The Front and Side Views in the Guardrail Post Assembly Detail should be revised to be consistent with the revisions made to the $\frac{3}{4}$ " base plate in Section B-B for the Screw Anchor Option.

RESPONSE: The Front view and Side view do not show the detailing of the screw anchor option. Section B-B shows how to modify the Standard detail for the screw anchor option. Adding both the screw anchor option and default linework to the other details would reduce clarity.

CHANGE MADE TO INDEX: No.

Response Date: 8/16/24

Name: Bon Soukamneuth

Date: 8/15/24

COMMENT: Shouldn't the notes and callouts say, "Screw or Expansion Anchors"?"

RESPONSE: The added option is only for Screw Anchors not Expansion Anchors.

CHANGE MADE TO INDEX: No.

Response Date: 8/16/24