
Index 460-472

Traffic Railing - (Thrie-Beam Retrofit) Wide Strong Curb Type 1

ORIGINATION

Date: 5/15/24

Name: Joshua Turley

Phone: 414-4475

Email: Joshua.turley@dot.state.fl.us

COMMENTARY

Sheets 1-4: Screw anchors are a new option that we are allowing and we have to indicate so in the Index.

COMMENTS AND RESPONSES

BLACK = Industry Review Comments **BLUE** = Standard Plans Response **GREEN** = Change Made to Index

Name: Bon Soukamneuth

Date: 8/15/24

COMMENT: Shouldn't the notes and callouts say, "Screw or Expansion Anchors"?"

RESPONSE: The added option is only for Screw Anchors not Expansion Anchors.

CHANGE MADE TO INDEX: No.

Response Date: 8/16/24