

---

## Index 630-010 Conduit Details - Embedded

### ORIGINATION

**Date:** 5/15/25

**Name:** Joshua Turley

**Phone:** 414-4475

**Email:** Joshua.turley@dot.state.fl.us

### COMMENTARY

Conduit height in the barrier is being limited to avoid conflicts with conduits when drilling holes for anchorage. This aligns with changes to Index 700-012, where the sign mounting plate was raised.

### COMMENTS AND RESPONSES

**BLACK** = Industry Review Comments   **BLUE** = Standard Plans Response   **GREEN** = Change Made to Index

**Name:** Katherine Chinault

**Date:** 8/4/25

**COMMENT:** Recommending the addition of a note that states “Adhere to minimum fiber bending radius requirements for conduits that will install fiber optic cable.”

**RESPONSE:** While it is a good idea to consider fiber optic bend radius limitations we should be more specific as to a maximum bend radius. The contractor may not know what the future use of the conduit may be or what type of fiber optic cable will be used. We will look into included a specific bend radius limit for a future revision.

**CHANGE MADE TO INDEX:** No.

*Response Date:* 8/5/25