
Index 520-020 Traffic Separators

ORIGINATION

Date: 2/24/2026

Name: Rick Jenkins

Phone: (850)414-4355

Email: rick.jenkins@dot.state.fl.us

COMMENTARY

Districts commented that the voids were undefined on the Standard Plans sheet. This revision helps to clarify what goes in the voids and provides a reference to the corresponding Standard Plan.

COMMENTS AND RESPONSES

BLACK = Industry Review Comments **BLUE** = Standard Plans Response **GREEN** = Change Made to Index

Name: Star Ayers

Date: 5/18/2026

COMMENT: Embankment Utilization Index 120-001 does not specifically address traffic separators. It does address medians which requires S. I am assuming the traffic separator will require S for backfill. SI 160-001 has Stabilization for full width under Traffic Separator. So, the full width will be stabilized, and type S will be the fill above the stabilization and under the concrete separator.

RESPONSE: The intent of the change is to show that the area under the separator is not a void and that Standard Plans Index 120-001 and the corresponding Specifications explain the embankment material and installation process.

CHANGE MADE TO INDEX: No.

Response Date: 6/3/2026