



# Florida Method of Test for Density of Slurry (Mud Weight)

**Designation: FM 3-D4380**

**FM 3-D4380** is identical to **ASTM D4380** except that the mineral slurry to be tested shall consist of processed attapulgite or bentonite clays, and the temperature of the slurry (using a 0-105°C thermometer) shall be measured and recorded on the Drilling Mud Report form.