

3460202 STRUCTURAL PORTLAND CEMENT CONCRETE

COMMENTS FROM INTERNAL/INDUSTRY REVIEW



John McKechnie

(850) 553-2236

john.mckechnie@dot.gov

Comments: (8-25-22 Industry)

Concur that revisions be made to the Materials manual to: Remove the Moderate Heat (MH) designation for consistency with AASHTO M85.

Response:

