

3460402 STRUCTURAL PORTLAND CEMENT CONCRETE
COMMENTS FROM INTERNAL/INDUSTRY REVIEW

.....
Please note the following comment was delivered outside the standard comment system and was subsequently missed during the response period.

Ronnie Hagan
850-330-1719

Ronnie.Hagan@dot.state.fl.us

Comments: (9-19-22 Industry)

Table 400-2 may need to change as well as section 400-17. There may be more. Any spec that has a 28-day strength as the guideline will need to change. 346-3.4 Acceptance of concrete at 56 days: Use concrete mix designs meeting the specified compressive strength at 56 days at the Contractor's option. Submit the request to the Engineer for approval. After the Engineer's approval, notify the concrete producer to initiate the mix design approval process at least 90 days prior to the anticipated concrete placement.

Response
