

3460402 STRUCTURAL PORTLAND CEMENT CONCRETE  
COMMENTS FROM INTERNAL/INDUSTRY REVIEW

.....  
Please note the following comment was delivered outside the standard comment system and was subsequently missed during the response period.

Ronnie Hagan  
850-330-1719

Ronnie.Hagan@dot.state.fl.us

Comments: (9-19-22 Industry)

Table 400-2 may need to change as well as section 400-17. There may be more. Any spec that has a 28-day strength as the guideline will need to change. 346-3.4 Acceptance of concrete at 56 days: Use concrete mix designs meeting the specified compressive strength at 56 days at the Contractor's option. Submit the request to the Engineer for approval. After the Engineer's approval, notify the concrete producer to initiate the mix design approval process at least 90 days prior to the anticipated concrete placement.

Response:(Specifications Office)

The State Materials Office discussed the comments with Ronnie Hagan (D3 Materials Office) and agreed to propose the modification to Section 400 in the next revision cycle. D3 Materials Office was satisfied with the response.

\*\*\*\*\*