

6760000 TRAFFIC CABINETS  
COMMENTS FROM INTERNAL/INDUSTRY REVIEW

Deborah Ihsan  
[deborah.ihsan@dot.state.fl.us](mailto:deborah.ihsan@dot.state.fl.us)  
954-777-4387

Comments: (8/31/22, Industry)

Consider adding the verbiage for weather tightness

**676-3.4 Small Enclosure Installation:** Mount the enclosure on a pole or support structure as shown in the Plans, and provide any hardware necessary for a complete and accepted installation.

Section 660 – Suggest adding information related to the labeling of wires within the cabinet similar to what is required for Traffic Cabinets in Section 676.

Response: Incorporated suggested edits as follows:  
Edited content in general section to clarify requirements for weather tightness apply to all cabinets, including small equipment enclosures.

\*\*\*\*\*