

## VOLUME II

### Section 6.3

## PRECAST CONCRETE DRAINAGE STRUCTURES AND BOX CULVERTS

### 6.3.1 PURPOSE

This procedure provides guidance for the development and implementation of the quality control for the manufacture, storage, and transportation of the precast concrete drainage structures and box culverts (Structures) for the Florida Department of Transportation projects. The Structures may include, but are not limited to, inlets, manholes, junction boxes, endwalls, three-sided precast concrete culverts, and precast concrete box culverts.

The Department will perform periodic quality assurance inspections, sampling, and testing to ensure of the quality and acceptability of the materials, methods, techniques, procedures and processes being utilized by the manufacturer in the fabrication of precast concrete products. The quality assurance inspection and testing will be performed in accordance with **Section 6.3, Volume I**, of the **Materials Manual**.

### 6.3.2 AUTHORITY

Sections 20.23(3)(a) and 334.048 (3), Florida Statutes.

### 6.3.3 REFERENCES

- (A) Design Standards Topic No. 625-010-003, Florida Department of Transportation.
- (B) American Society for Testing and Materials (ASTM) Standard Test Methods and Specifications, Philadelphia, Pennsylvania.
- (C) American Association of State Highway and Transportation Officials (AASHTO), Part I Specifications, and Part II Tests, Washington, D.C.
- (D) Florida Department of Transportation Standard Specifications for

Road and Bridge Construction.

- (E) Qualified Products List, Florida Department of Transportation.
- (F) Field sampling and Testing Manual, Florida Department of Transportation.

### **6.3.4 SCOPE**

This procedure is used by the Precast Concrete Structures Plants (Plants). These requirements and activities pertain to the inspections, measurements, and necessary tests to substantiate materials and Structures in conformity with the Contract Documents. The Plant's quality control plan is designed to provide guidelines that are used by Plants to produce Structures in conformance to Department's **Specifications** and project plans.

### **6.3.5 GENERAL INFORMATION**

The Plants are responsible for the production, inspection, storage, and shipment of the Structures. The delivered Structures to the project site shall meet the requirements of the Department's **Specifications**, plans, and other Contract Documents.

### **6.3.6 PLANT QUALIFICATION PROCESS**

#### **6.3.6.1 General**

Submit the proposed quality control plan in accordance with **Materials Manual Section 5.6** to the District Materials Office for review and acceptance and make arrangement for qualification review of the Plant prior to commencement of any work for the Department projects.

#### **6.3.6.2 Review of Plant's Proposed Quality Control Plan**

Submits the proposed quality control plan to the Department's District Materials Office for the District in which the Plant is located. For out-of-state Plants, submit the quality control plan to the Department's nearest District Materials Office. Upon the Plant's submittal of a quality control plan, the District Materials Office will review the proposed quality control plan and make necessary arrangements for the initial Plant qualification review in accordance with **Materials Manual Section 6.3.6.3**.

In the quality control plan include the work experience, qualifications, and

responsibilities of the Plant's production and quality control personnel. Identify the on-site production manager, Plant general manager, quality control inspectors/technicians, and quality control manager. Identify the key quality attributes in the quality control plan. Identify the responsibilities for monitoring key quality attributes and quality control data. Include the applicable information required in **Sections 6, 105, 407, 410, and 449** of the **Florida Department of Transportation Specifications**. Include a management statement of dedication to quality. Include any available proposed repair methods for minor deficiencies as part of the quality control plan.

The National Precast Concrete Association (NPCA) certified Plants may submit the document entitled "**NPCA Quality Control Manual for Precast Plants (NPCA Manual)**" as their quality control plan. In their submittal, the NPCA certified Plants include a statement that the Plants will comply with the requirements of the **NPCA Manual**. The Department specifications and other Contract Documents will govern, when there is a discrepancy between the **NPCA Manual** and Department specifications. Submit any additional information, which is required by this Section of the Materials Manual, but are not included as part of the **NPCA Manual**, as an addendum to the **NPCA Manual**. When requested by the Department Inspectors, the NPCA certified Plants are required to provide the two most recent NPCA inspection reports, including the Plant's responses to the deficiency reports, if applicable.

#### **6.3.6.3 Plant Qualification Review**

The Department will perform the initial Plant qualification review of the production facilities. An initial review includes an in-depth inspection by the Department of a Plant that submits its first quality control plan and Plants that have not produced Structures for the Department projects for more than a year. Upon the approval of the Plant's quality control plan, the Department will also perform routine, at least quarterly, verification inspections, and Plant qualification reviews, at least annually, on all Plants that have continued to furnish Structures for the Department projects.

#### **6.3.6.4 Maintenance of Plant Qualification**

Upon the Department's satisfactory review of the proposed quality control plan, in compliance with **Section 5.6** of the **Materials Manual**, and satisfactory Plant qualification review, the District Materials Office will accept (approve) the proposed quality control plan and include the Plant on the list of Department's qualified Plants. Immediately notify the District Materials Office in writing of any changes to the quality control plan. In

case of change(s), revise the quality control plan annually in the form of addenda or complete revision of the entire document. Submit the revised quality control plan or its addenda to the District Materials Office annually.

Plants that are on the Department's accepted quality control plan list will be subject to the Plant qualification review process at any time. The Plant qualification review team will perform at least one annual in-depth review of the Plant that is producing for the Department projects.

## **6.3.7 FUNCTIONS AND RESPONSIBILITIES OF PRECAST CONCRETE PLANTS**

### **6.3.7.1 General**

The Plants are responsible for the quality of the finished Structures. Provide facilities and qualified quality control personnel to perform specified tests and maintain an acceptable quality control program in compliance with the requirements specified herein and in **Sections 407, 410, and 449** of the *Florida Department of Transportation Specifications*.

### **6.3.7.2 Quality Control Manager**

The quality control manager shall ensure that the quality of the products at each Plant meets the quality requirements of the Contract Documents. The quality control manager may serve in more than one Plant. The responsibilities of the quality control manager include, but are not limited to, the following:

- (A) Maintains the quality control approval stamp and applies it to acceptable Structures, or designates a technician, who is working under the direct supervision of the quality control manager, to apply the Plant approval stamp. The Plant approval stamp mark shall be legible and applied to each Structure before its shipment to the project site.
- (B) Be present, or designates a quality control technician/inspector working under the direct supervision of the quality control manager, to be present, all times, during the production of all Structures that will be shipped to Department projects.
- (C) Performs and/or supervises the quality control testing and inspection.
- (D) Ensures that the Plant has a sufficient number of quality control

technician(s)/Inspector(s) to maintain adequate inspection and testing during the production of Structures for Department projects. In lieu of a permanent staff, the Plant may retain the services of an engineering consulting firm or qualified laboratory meeting the requirements of **Sub-article 6-9** of the **Florida Department of Transportation Specifications** and quality control personnel qualification of this Section.

- (E) Ensures that testing equipment is properly maintained in accordance with the applicable test methods and specifications. Makes readily available, the current certification on testing equipment that is requiring calibration.
- (F) Visually inspects or ensures that a qualified quality control technician inspects each Structure before it is shipped to the project site.
- (G) Ensures that all materials used to manufacture Structures are from a Department approved source.
- (H) Maintains a daily production log of the manufactured Structures.
- (I) Ensures that all Structures are properly stored and marked indelibly with Plant name and number, Structure number that is traceable to the Department project, and date of Manufacture.
- (J) Maintains the quality control files of material certifications, test data, and inspection results.
- (K) Arranges monthly meetings with the Department's Verification Inspector and representatives of the Plant's production personnel to discuss any deficiencies and quality control issues.

When the Plant's assigned quality control manager discontinues his/her work without advanced notice, the Plant shall notify the District Materials Office within two-working days and employ reasonable efforts to seek a replacement. During such efforts to seek a replacement, the Plant engineer, technician, or other knowledgeable person designated in the Plant's quality control plan may perform the duties of the quality control manager for a period established by the District Materials Engineer, based on efforts employed by the Plant to seek a qualified replacement and/or training another person leading up to the next available Department accredited training/certification programs.

### **6.3.7.3 Technicians/Inspectors**

The quality control technicians may perform any or all of the inspections, sampling, or testing as directed by the quality control manager, and may stamp the Plant approved Structures, when directed by the quality control manager.

### **6.3.7.4 Quality Control of Certified Materials**

#### **6.3.7.4.1 General**

Ensure that all materials used to manufacture of Structures are from Department approved sources and comply with requirements as specified herein.

#### **6.3.7.4.2 Reinforcing Steel and Welded Wire Reinforcement**

The quality control inspectors shall obtain steel Plant's certifications for all welded wire reinforcement and reinforcing steel that are used to manufacture Structures. These certifications shall indicate compliance with the appropriate ASTM or AASHTO standards for wire, wire reinforcement and for steel bars. Upon request, provide samples for the Department Verification Inspectors at each Plant, from at least two randomly selected LOTs per year. The Department will perform the testing of these samples. A LOT is a single vehicle load of the reinforcing steel or welded wire fabric of the same grade and Plant that is delivered to the Plant. Reinforcing steel shall meet the requirements of **Section 415** of the **Florida Department of Transportation Specifications**.

#### **6.3.7.4.3 Coarse and Fine Aggregates**

The aggregates delivery tickets shall include the following information:

- (A) Name of the approved producer
- (B) Location of mine
- (C) Department pit number
- (D) Department material code
- (E) Delivery date
- (F) Aggregate producer's statement with each shipment indicating that the shipped products comply with Department

specifications.

Maintain each size of aggregates and mine sources in separate stockpiles. Each stockpile shall have Department Identification pit number. Prevent the contamination, segregation, or intermingling of stockpiled aggregates of different sizes with each other.

#### **6.3.7.4.4 Cement**

Accept the delivered cement on the basis of the cement producer's certification. The certification shall indicate compliance with **Section 921 of the Florida Department of Transportation Specifications**. A certification for each shipment of cement is required. Verification samples may be obtained at the discretion of the District Materials Engineer. Cooperate with Verification inspector in obtaining the cement sample.

#### **6.3.7.4.5 Pozzolans and Slag**

Accept the ground granulated blast furnace slag on the basis of the supplier's certification indicating compliance with **Section 929 of the Florida Department of Transportation Specifications** and other Contract Documents. A certificate for each shipment of pozzolans and slag is required. Department Verification Inspectors may take a sample at Plant or Producer's source. Cooperate with Verification inspector in obtaining the required sample of the supplemental cementitious materials.

#### **6.3.7.4.6 Batch Water**

Water used for mixing concrete shall comply with **Section 923 of the Florida Department of Transportation Specifications**. The record of the well water testing will be maintained on file.

#### **6.3.7.4.7 Chemical Admixtures**

Admixtures shall meet the requirements of **Section 924 of the Florida Department of Transportation Specifications**. The Department allows the use of admixtures by one of the following qualification process:

- (A) The admixtures that are listed in the **Florida Department of Transportation Specifications, Sub-article 924-2** are

required to be on the Department's Qualified Products List. The manufacturer shall use the products that are included as part of this list.

- (B) As part of the Plant's quality control plan, the District Materials Office reviews and approves the use of the admixtures that are used for workability, the ease of machine processing, and better consolidation of dry-cast concrete Structures and other machine- formed concrete products. The approval of the admixture as part of the Plant's quality control plan indicates that the admixture has been given contingent approval, as evidenced by previous tests and its apparent effectiveness under field conditions. This approval will continue as long as the admixture performs as claimed. For the use of reinforced concrete products, the concrete admixtures shall not contain calcium chloride or calcium chloride- based ingredients.

#### **6.3.7.4.8 Resilient Connectors for Sealing Structures to Pipe Joints**

The resilient connectors shall conform to the requirements of **Section 942 of the Florida Department of Transportation Specifications**. Maintain a copy of the certification of compliance in the Quality Control file.

#### **6.3.7.4.9 Resilient Connector Lubricant**

Ensure that the producers of the resilient connector lubricant provide a certification statement indicating compliance with requirements of Contract Documents.

#### **6.3.7.4.10 Patching Materials**

All patching compounds shall comply with **Section 449 of the Florida Department of Transportation Specifications**. Pre-mixed packaged compounds may be used, when it is listed on the Qualified Products List or approved by District Materials Office as part of the Plant's quality control plan. The approval of the repair material as part of the Plant's quality control plan indicates that the use of the material has been given contingent approval, as evidenced by previous tests and its apparent effectiveness under field conditions. This approval will continue as long as the patching product performs as claimed. The approval of the patching products by the District Materials Office is restricted to those products which do not belong to any category of the Qualified



Products List and Department has not developed a specification for such products. The approval will remain in effect until such times as a specification is developed for the review and approval process of these products.

#### **6.3.7.5 Quality Control of Concrete Production and Placement Equipment**

Ensure that the batching and mixing equipment be capable of properly proportioning and mixing the various ingredients into a uniform mixture. Use adequate means for casting, consolidation, and curing of concrete.

#### **6.3.7.6 Calibration of Equipment**

Check or calibrate all quality control testing equipment such as the batching scales, compressive strength testing machines, portable weighing scales, air meters, density buckets, and temperature recording devices for compliance with the applicable test methods.

#### **6.3.7.7 Quality Control of Structures Manufacturing Process**

The following are quality control inspections and testing, related to operations prior to, during, and after concrete placement.

##### **6.3.7.7.1 Concrete Mix Design**

Unless otherwise shown on the Plans or required by the specifications, the concrete mix produced for the manufacture of project Structures shall comply with the requirements specified in **Section 449 of the Florida Department of Transportation Specifications** and the following documents:

- (A) **ASTM C 478** for manholes, inlets, and endwalls
- (B) **Sections 346 and 407, of the Florida Department of Transportation Specifications** for the three-sided precast culvert.
- (C) **Section 410 of the Florida Department of Transportation Specifications** for Box Culverts.

The mix design information shall include the source of aggregates, cementitious materials, and admixtures, along with the proportions

of all concrete ingredients. Include the Department approved mix designs as part of the approved quality control plan.

#### **6.3.7.7.2 Structure Materials Storage**

Properly handle and store aggregates to minimize the segregation of particle size and prevent contamination.

Store all reinforcing steel according to ***Section 415 of the Florida Department of Transportation Specifications***.

#### **6.3.7.7.3 Forms**

Ensure that the condition of all forms be of a quality to produce acceptable Structures within the dimensional tolerances. The quality control inspector shall check cleanliness of the forms prior to each use. Check the form dimensions prior to its first use and at least annually for dimensional conformance.

#### **6.3.7.7.4 Reinforcing Steel Placement**

Ensure that the reinforcing steel placement meets the requirements of ***Section 415 of the Florida Department of Transportation Specifications***. Prior to the concrete placement, check the fabrication, positioning, and minimum concrete cover requirements of steel reinforcement on all types of manufactured Structures. Ensure that that the steel reinforcement meets the specification requirements. Check the minimum steel area requirements for Structures in accordance with the applicable design standards such as AASHTO, ASTM, or approved shop drawings.

#### **6.3.7.7.5 Concrete Mixture and Placement Operation**

Mix, deliver, and place concrete in accordance with the applicable standards to produce a homogeneous concrete.

#### **6.3.7.7.6 Concrete Curing**

Cure the Structures in accordance with the applicable curing methods that is included as part of the quality control plan.

### 6.3.7.8 Quality Control Testing and Inspection of Structures

#### 6.3.7.8.1 General

Perform the quality control inspection and tests at the frequencies and LOT (Group) sizes that are specified in the applicable sections of the Department's Specifications and other applicable Contract Documents.

The quality control plan shall include the Quality Control test methods, inspections, and minimum frequency and LOT sizes of tests that are used as the basis of acceptance of each type of Structures. The quality control inspectors shall obtain randomly selected samples from each LOT in accordance with the applicable Sections of Department's Specifications, not to exceed 50 Sections of the Structures per LOT.

Each LOT of the Structures components is accepted when:

- (A) The test results and inspections meet the requirements as specified herein and in the applicable specifications.
- (B) The Plant has completed all patching and repair work.
- (C) The Quality Control Manager or his/her designated technician has stamped the Structures.
- (D) The list of the Structures is included with each shipment of the products to the project site.

#### 6.3.7.8.2 Compressive Strength of Test Cylinders

Sample and test concrete in accordance with **Section 346** of the **Florida Department of Transportation Specifications**, when the Plant is using the **Section 346** concrete class. Use 6 x 12-in [150 x 300] or 4 x 8-in [100 x 200-mm] test cylinders for the compressive strength tests of concrete. Include the selected cylinder size or sizes in the mix design form. Each day's concrete production is comprised of one LOT (or more LOTs per Plant's quality control plan), when the **ASTM or AASHTO** class of concrete is used for manufacturing of precast reinforced concrete inlets, manholes, and junction boxes.

### 6.3.7.8.3 Absorption Test

**Section 8.2.2 of ASTM C 478** is modified to waive the absorption test requirements of the precast reinforced concrete inlets, manholes, junction boxes, and endwalls.

### 6.3.7.8.4 Appearance and Inspection of Final Finished Structures

The quality control manager or his/her designee performs final quality control inspection of the finished Structures, before the application of the quality control approval stamp, to ensure that the Structures are free from deficiencies and meet the specified dimensional tolerances. Forms used to manufacture Structures shall be sufficiently rigid and accurate to maintain the Structures designed dimensions and avoid irregularities in their surfaces. Structures may be repaired if necessitated by occasional imperfections in the manufacture or damage during handling, and will be considered acceptable if the repairs are sound and properly finished to conform to the dimensional tolerances of the specifications. Submit the proposed repair method for Department review and approval. Use the repair material from the Department qualified products list or any other approved method. Include all Department approved material and methods as part of the Plant's quality control plan. Dimensional tolerances shall comply with the applicable requirements of ASTM or AASHTO standards, except as modified in **Section 449 of the Florida Department of Transportation Specifications**.

The Quality Control inspectors shall perform visual inspection of all finished Structures, measure the dimensions of at least 20% of the randomly selected units in each LOT, and maintain a record of the inspections, including the deficiencies. Minor deficiencies may be repaired in accordance with the repair methods included as part of the quality control plan. The repair of major damage to a Structure requires engineering evaluation meeting the requirements of **Sub-article 450-14 of the Florida Department of Transportation Specifications**. The Plant shall determine the cause of the repetitive nonconformance and develop a corrective action plan. Submit the revised quality control plan to address the type of deficiencies and corrective action that will be taken to prevent or minimize the deficiencies.

### 6.3.7.8.5 Repair of Precast Concrete Structures

The Plant's quality control manager shall examine and determine the magnitude of the deficiency. The quality control manager may authorize the immediate repair of minor deficiencies in accordance with the repair method that is included as part of the quality control plan. Perform the repair under the observation of the quality control manager or under the observation of personnel working under his/her direct supervision. The Plant's quality control personnel shall document the type of deficiency and its repair method.

#### **6.3.7.8.6 Handling and Storage**

Handle and store all Structures properly to prevent damage. The quality control inspectors shall inspect the Structure handling operations and appropriate practices that will prevent damage. The quality control inspectors shall inspect Structures during storage to ensure that they are stored correctly and are not being damaged by point loading or stacking too high. Do not store the rejected Structures in the same area with the acceptable Structures. Rejected Pipe shall be culled and marked as rejected.

#### **6.3.7.8.7 Stamping**

The quality control inspector shall inspect the identification and stamp marks on the wall of the Structures to ensure that they are valid stamp marks. The Plant shall affix the Plant's quality control stamp to each section of Structure, indicating that the manufactured Structure meets the requirements of the Contract Documents and Plant's quality control plan. A copy of the certification statement from the general manager of the Plant shall be included in the quality control plan regarding the stamp configuration.

#### **6.3.7.8.8 Shipment**

Address the Plant's shipping policy as part of the quality control plan.

Ensure that at the beginning of each project, the Plant provides a notarized statement to the Department project administrator from a responsible company representative certifying that the Plant will manufacture the products in accordance with the requirements set forth in the Contract Documents and Plant's approved quality control plan. The quality control manager's stamp on each product indicates certification that the product was fabricated in

conformance with the Contractor's quality control plan and Contract Documents. Ensure that each shipment of precast concrete products to the project site is accompanied with a signed or stamped delivery ticket providing the description and the list of the products.

The list of the product with each delivery ticket shall be on the Plant's letterhead and shall include as a minimum:

- (A) Project Number
- (B) Date shipped
- (C) Serial Number of the Structure section

The quality control manager or quality control personnel working under the direct supervision of the quality control manager shall stamp each Structure prior to its shipment to the project site. The quality control stamp indicates that the Plant certifies that the Structure was manufactured in conformance with the Plant's quality control Plan. Each shipment of the Structures to the project site shall include the list of the Structures. The Plant shall address the shipping policy as part of the quality control plan.

#### **6.3.7.8.9 Documentation**

The quality control manager shall maintain documentation files in each Plant. Maintain these documents for a period of not less than three years after the last delivery of the Structures to the project site. The quality control documentation shall as a minimum include the following items:

- (A) A copy of the approved quality control plan
- (B) Approved shop drawings (if applicable)
- (C) Applicable ASTM and AASHTO standards
- (D) Applicable Department Specifications and Design Standards
- (E) Quality control personnel training and qualification records
- (F) Materials certification records for cement, aggregates, cementitious materials, chemical admixtures, reinforcing steel, and welded wire reinforcement.
- (G) Concrete Mix designs
- (H) Equipment calibration, including concrete batching

equipment, water meter, admixture dispensing equipment, concrete compression testing machine, and laboratory scales. The batch plants furnishing concrete in accordance with **Section 346 of the Florida Department of Transportation Specifications** are required to meet the requirements of **Section 9.2 of the Materials Manual**. For ASTM or AASHTO classes of concrete, perform the calibration of the testing machine and batch equipment in accordance with the applicable ASTM/AASHTO standards or equipment manufacturers' recommendation.

- (I) LOT number identification of each product
- (J) Number and type of Structures
- (K) Applicable test data
- (L) Disposition of all manufactured Structures
- (M) Record of the delivery tickets of each shipment of the products to the job site.
- (N) Record of all structural deficiencies found as a result of quality control inspection and testing or Verification inspection and testing and the corrective action taken. A copy of the deficiency reports shall also be maintained in the Plant's permanent file.

## **6.3.8 TRAINING**

### **6.3.8.1 General**

The Plant's quality control personnel who are involved in the inspection and testing of the precast concrete drainage structures and precast concrete box culverts shall have the required qualifications as specified herein.

The applicants shall attend a Department accredited precast concrete training course and receive a passing grade on the final examination for the course. Ensure that the Plant's quality control plan includes training certification copies for their qualified quality control personnel.

The State Materials Office maintains the list of the accredited precast concrete courses.

### **6.3.8.2 Quality Control Personnel of the Precast Concrete Drainage Products and Precast Concrete Box Culverts**

Ensure that all personnel performing the quality control inspection and testing of the precast concrete products at a manufacturing facilities, have the required qualifications as described herein:

#### **6.3.8.2.1 Level I Quality Control Inspectors**

Level I quality control inspectors are those who are performing the routine concrete inspection and testing of the precast concrete drainage products and box culverts, including, concrete materials, pre-pour form and reinforcing steel placement inspections, concrete batching, mixing, placement, and post-placement inspections. The quality control inspectors shall be familiar with the precast concrete related plans and specifications and have completed a minimum of 12-hour, Department approved, training course, including the examination.

Prerequisites: The personnel performing the plastic property tests are required to have the ACI Concrete Field Testing Technician, Grade I, certification. The personnel who are performing the laboratory concrete tests are required to have ACI Level I Concrete Laboratory Technician- Grade I certification. The personnel who are performing only concrete Strength Tests are required to have either ACI Level I Concrete Laboratory Technician- Grade I certification or ACI Concrete Strength Testing Technician certification.

#### **6.3.8.2.2 Level II Quality Control Inspectors**

Level II inspectors are those who are involved in the design and verification of the concrete mixes and evaluate the needed repair method and its implementation. Advanced knowledge of the shop drawings, specifications, test methods, and Standard Indices are the requirements for Level II qualifications. Ensure that Level II Inspectors have Level I Quality Control Inspector certification and have successfully completed a minimum of additional 5-hour, Department approved course, including the examination.

#### **6.3.8.2.3 Concrete Batch Plant Operator**

The Batch Plant Operator shall have a Construction Training Qualification Program (CTQP) batch plant operator certification or complete a minimum of 6-hour, Department approved course,



including the examination.

The batch plant operator shall have a general knowledge of concrete and its materials ingredients, including the following:

- (A) Concrete specification requirements related to batch plants
- (B) Batch plant qualification process,
- (C) Concrete mix design adjustments based on moisture content of the aggregates
- (D) Preparation of the delivery ticket
- (E) Batch plant mixer and other equipment inspections
- (F) Scale and meters calibration requirements
- (G) Maintaining of batch plant records.

#### **6.3.8.2.4 Quality Control Managers of Precast Concrete Drainage Products Plant and Box Culverts**

The Quality Control Managers shall have Precast Concrete Drainage Products and Box Culvert Plant- Level II Quality Control Inspector certification and a minimum of two years of experience, directly related to cement concrete production.

#### **6.3.8.3 Re-qualification of the Quality Control Personnel and Department Inspectors:**

The Level I and II qualifications will expire at the end of five years, during which, the inspectors have the choice of attending the course and retaking the examination or only they take the examination to be re-qualified for an additional five years.

#### **6.3.9 FORMS**

There are no forms associated with this procedure.