

4000507 CONCRETE STRUCTURES
COMMENTS FROM INTERNAL/INDUSTRY REVIEW



Keith Waugh
352-787-1616
kwaugh@lewarecc.com

Comments: (7-12-19)

Note 1 should apply to Non-cellular form with concrete filled flutes in Slightly Aggressive environment.

Response: Our initial proposed revisions were not correct. Note 1 only needs to be applied to the case where a non-cellular form has polystyrene foam filled flutes at the interior supports on continuous decks, while the remainder of the form has concrete in the flutes.

Line 1 of the Table does not require polymer sheeting on the top side of the form for any environmental classification, therefore Note 1 is not needed. Note 2 is needed on Line 1 for moderately and extremely aggressive environments if the form is located within a box girder or U-beam.

Note 1 is needed on Line 2 for all environmental classifications. Note 2 is needed on Line 2 for moderately and extremely aggressive environments.

Changes made.
