

6770201 EQUIPMENT SHELTER
COMMENTS FROM INTERNAL/INDUSTRY REVIEW

Pedro Rodriguez
305-514-3399
pedro.rodriquez@atkinsglobal.com

Comments: (6-18-19)

1. 677-2.4 Walls - My concern is that if the vapor shield is applied to the inside face of the concrete wall, moisture could be trapped. Moisture trapped between the inside vapor shield and the outside painted surface could promote mold growth within the wall.

Response:

2. 677-2.5 Ceiling and Roof - My concern is that if the vapor shield is applied to the inside face of the concrete roof, moisture could be trapped. Moisture trapped between the inside vapor shield and the outside painted surface could promote mold growth within the roof.

Response:
