

9290000 POZZOLANS AND SLAG  
COMMENTS FROM INTERNAL/INDUSTRY REVIEW

Joseph Conover  
239-825-3574  
[josephp.conover@cemex.com](mailto:josephp.conover@cemex.com)

Comments: (4-26-19, Internal)

929-2.5, third line – change “5%” to “5.0%”. This makes it clear that an LOI reaches 5.1%, the additional testing is required. ASTM C618 - Standard Specification for Coal Fly Ash and Raw or Calcined Natural Pozzolan for Use in Concrete test per ASTM C311 – Standard Test Methods for Sampling and Testing Fly Ash or Natural Pozzolans for Use in Portland-Cement Concrete which requires calculating the loss on ignition “to the nearest 0.1%.” (14.1)

Response:

\*\*\*\*\*

Thomas Frank  
352-955-6683  
[thomas.frank@dot.state.fl.us](mailto:thomas.frank@dot.state.fl.us)

Comments: (5-30-19)

929-3.4 Stating that the reference cement used to measure slag activity index must meet ASTM C989 is unnecessary. The earlier sentence stating that the slag must meet the physical and chemical requirements of ASTM C989 is sufficient. It is understood that means all of the requirements therein, for enforcement purposes.

Response:

\*\*\*\*\*