

4550300 STRUCTURES FOUNDATIONS
COMMENTS FROM INTERNAL/INDUSTRY REVIEW

Stefanie Maxwell
(850) 414-4140

Stefanie.Maxwell@dot.state.fl.us

Comments: (5-18-20, Internal)

Please add the two commas highlighted in yellow below.

455-3 Description.

Furnish and install concrete, steel, or wood piling including driving, jetting, preformed pile holes, cutting off, splicing, dynamic load testing, and static load testing of piling. Prior to driving, clearly mark the piles to facilitate inspection. Provide individual straight-line marks at 1-ft intervals numbered at least every 5 ft. Use markers or lumber crayons that can be easily observed by the inspector. Ensure marks are spaced uniformly and perpendicular to the face of the pile. When set checks or practical refusal checks are required, provide inch marks as directed by the Engineer.

Response: Change was made.
