

5210100 CONCRETE BARRIERS, TRAFFIC RAILINGS, AND PARAPETS
COMMENTS FROM INTERNAL/INDUSTRY REVIEW

Sherry Valdes
414-4249
sherry.valdez@dot.state.fl.us

Comments: (10-5-18)

Please remove 2nd sentence under "Method of Measurements". Plan Quantity is not a measured item. Please ensure that the language in the 2nd sentence is included in the FDM. OR the 2nd sentence could change to: The plan quantity is calculated along the centerline of the rigid barrier from begin to end station, including transitional and end sections, with no deduction for expansion joints, open joints, or leave-outs. I still think that should be included in the FDM.

Response:
