

5210100 CONCRETE BARRIERS, TRAFFIC RAILINGS, AND PARAPETS  
COMMENTS FROM INTERNAL/INDUSTRY REVIEW

Sherry Valdes  
414-4249  
[sherry.valdez@dot.state.fl.us](mailto:sherry.valdez@dot.state.fl.us)

Comments: (10-5-18)

Please remove 2nd sentence under "Method of Measurements". Plan Quantity is not a measured item. Please ensure that the language in the 2nd sentence is included in the FDM. OR the 2nd sentence could change to: The plan quantity is calculated along the centerline of the rigid barrier from begin to end station, including transitional and end sections, with no deduction for expansion joints, open joints, or leave-outs. I still think that should be included in the FDM.

Response: The quantity tabulation method is appropriately placed in the Method of Measurement section because contractors require this information to tabulate quantities, and designers will have access to this information as well. Also, the location of this measurement information is not a proposed revision, so it is beyond the scope of these revision comments for the current stage of the next eBook release. The proposed 521-8 will remain as-is.

\*\*\*\*\*