

5270301 DETECTABLE WARNINGS
COMMENTS FROM INTERNAL/INDUSTRY REVIEW

Ananth Prasad
(850 942-1404 ext 5

Comments: (Internal, 11-6-18)

1. What defines “cured”. Is there a set time period after placement?
2. If the sidewalk is not to be opened to pedestrian traffic yet, why does the detectable warning need to be applied “as soon as the sidewalk has cured”. Should language say “*Install surface applied tiles or mats after sidewalk concrete has cured and before opening to pedestrian traffic*” or something along those lines?

Response:

1. The cure time is dependent on the type of detectable warning used. The preceding sentence says to follow the manufacturer’s instructions for installation. No change made.
2. Agree, proposed change was made.
