4610300 MULTIROTATIONAL BEARINGS COMMENTS FROM INTERNAL/INDUSTRY REVIEW

David Booher 863-422-5517 dbooher@quiggengineering.com

Comments: (10-11-19, Industry) New sentence conflicts with previous existing sentence. May want revise new sentence to state: Detail all steel bearing components with sliding surfaces (e.g. plates with attached stainless-steel or Teflon plates) and elastomeric components to be replaceable. Welded attachments are not considered replaceable.
