

**ORINATION FORM**  
**Proposed Revisions to the Specifications**

(Please provide all information - incomplete forms will be returned)

Date:

Office:

Originator:

Specification Section:

Telephone:

Article/Subarticle:

email:

**\*\*Will the proposed revision require changes to:**

<b>Publication</b>	<b>Yes</b>	<b>No</b>	<b>Office Staff Contacted and date contacted</b>
Standard Plans Index			
Traffic Engineering Manual			
FDOT Design Manual			
Construction Project Administration Manual			
Basis of Estimate/Pay Items			
Structures Design Guidelines			
Approved Product List			
Materials Manual			

\*\*This section must be completed prior to processing proposed revisions.

**Will this revision necessitate any of the following:**

**Design Bulletin**

**Construction Bulletin**

**Estimates Bulletin**

**Materials Bulletin**

**Are all references to external publications current?**

**Yes**

**No**

**If not, what references need to be updated? (Please include changes in the redline document.)**

**Why does the existing language need to be changed?**

**Summary of the changes:**

**Are these changes applicable to all Department jobs?**

**Yes**

**No**

**If not, what are the restrictions?**



*Florida Department of Transportation*

RON DESANTIS  
GOVERNOR

605 Suwannee Street  
Tallahassee, FL 32399-0450

KEVIN J. THIBAUT, P.E.  
SECRETARY

**MEMORANDUM**

**DATE:** November 21, 2019

**TO:** Specification Review Distribution List

**FROM:** Daniel Strickland, P.E., State Specifications Engineer

**SUBJECT:** Proposed Specification: **5560403 Jack and Bore.**

In accordance with Specification Development Procedures, we are sending you a copy of a proposed specification change.

This change was proposed by Jason Russell from the State Construction Office to clarify the testing requirements.

Please share this proposal with others within your responsibility. Review comments are due within four weeks and should be sent to Mail Station 75 or online at <http://fdotewp1.dot.state.fl.us/programmanagement/development/industryreview.aspx> . Comments received after **December 26, 2019**, may not be considered. Your input is encouraged.

DS/rf  
Attachment

**JACK AND BORE  
(REV 11-6-19)**

SUBARTICLE 556-4.3.2 is deleted and the following substituted:

**556-4.3.2 Drainage Application Testing (Under Pavement):** When under pavement (including sidewalk) and front shoulders, all J&B pipe installations must meet or exceed the Department's water-tight pipe and joint configuration in accordance with Section 430. The Engineer will determine when and where water-tight joint requirements shall be applied to the ultimate roadway section for future widening. For all J&B carrier pipes installed without casing under pavement, perform air pressure testing at 5 psi in the presence of the Engineer as follows. ~~When under the pavement, conduct an air pressure test for leaks in the presence of the Engineer at a minimum test pressure of 20 psi by either of the following methods:~~

1. Pressurize pipe to 5 psi and lock-off outside air source. Record pressure loss for 6 hours. A pressure loss equal to or less than 0.5 psi is acceptable. ~~24-hour pressure test with a recording chart~~ or,

2. A dragnet type leak detector or equivalent device capable of detecting pressure drops of 1/2 PSI for a time period recommended by the manufacturer. If the pressure loss exceeds 0.5 psi, repair leaks using methods approved by the Engineer and retest.

SUBARTICLE 556-4.3 is deleted and the following substituted:

**556-4.3. 4 Damaged Product Testing:** When there is any indication that the installed product has sustained damage and may leak, stop the work, notify the Engineer and investigate damage. The Engineer may require a pressure test in accordance with 556-4.3.2. ~~and reserves the right to be present during the test.~~ Perform pressure test within 24 hours unless otherwise approved by the Engineer. Submit the test results to the Engineer for review and approval. The Engineer shall be allowed up to 72 hours to approve or determine if the product installation is not in compliance with Specifications. The Engineer may require non-compliant installations to be filled with excavatable flowable fill at no cost to the Department.

SUBARTICLE 556-6.1 is deleted and the following substituted:

**556-6 Documentation Requirements.**

**556-6.1 Boring Path Report:** Submit a bore path report to the Engineer within 14 days of the completion of each bore path. No payment will be made for directional boring work until the bore path report has been delivered to the Department. Include the following information in the report:

1. Location of project and financial project number including the permit number when assigned.
2. Name of person collecting data, including title, position and company name.
3. Investigation site location (Contract Plans station number or reference to a permanent structure within the project right of way).

4. Identification of the detection method used.

5. Spoils removal log.

6. As-built placement plans showing roadway plan and profile, cross-section, boring location and subsurface conditions as defined in bore path plans below. Reference the shown plan elevations to a Department bench-mark when associated with a Department project, otherwise to a USGS grid system and datum or to the top of an existing Department head wall.