

9330103 PRESTRESSING STRAND AND BAR  
COMMENTS FROM INTERNAL/INDUSTRY REVIEW

.....  
Art Berger  
Arthur.Berger@dot.state.fl.us

Comments: (12-2-19, Internal)

**933-5.2.2.1 Material Acceptance:** Submit to the Engineer a certificate of analysis for each production LOT from the producer of the CFRP strand, confirming compliance with the requirements of this Section.

Response:

\*\*\*\*\*