

9620800 STRUCTURAL STEEL AND MISCELLANEOUS METAL ITEMS (OTHER THAN ALUMINUM)

COMMENTS FROM INTERNAL/INDUSTRY REVIEW



Arthur Berger

Arthur.Berger@dot.state.fl.us

Comments: (12-9-19, Internal)

Is it understood from other specifications in the Standard Specifications that this is a minimum standard, and that a higher standard can be provided?

At a minimum, provide Grade 50 steel per ASTM A242/A242 M, A572/A572 M

Response:



Chase Knight

(352) 955-2901

Chase.Knight@dot.state.fl.us

Comments: (12-9-19, Internal)

Otherwise, I noticed the followed error that I missed:

“ASTM A242/A242 M, A572/A572 M or A588/A588 M for grates.”

Response:

